

Unexpected Accumulation of Naturally Occurring Radionuclides in a Petrochemical Plant



Gert Jonkers
Independent Consultant


Unexpected Accumulation of NOR's in a Petrochemical Plant Events

- ❑ Container with scrap of a Polyol Plant (PP-NL) triggers portal monitor alarm at Scrap Dealer.
- ❑ Notification of VROM-Inspection Region South-West.
- ❑ Contractor investigation of contents of PP-NL scrap container (dose rate outside container 0.15 $\mu\text{Sv/h}$ at maximum).
- ❑ Approval from VROM to transport a C/S candle to SRTCA for investigations




Coalescer/Settler (C/S) Candles

C/S Candle β/γ External Radiation




Polyol Plant NL

Simplified Flow Scheme Plant (partly)




C/S Candles

Construction and Operation



Polyol Plant NL

Controlled Dismantling C/S Candle



Grab Sample Deposits, ex C/S Candles PP-NL

Gamma-Spectroscopic Analysis

identification and quantification of Naturally Occurring Radionuclides (**Bq[NOR]/g**)

^{40}K	1.5				
^{232}Th	< det lim ^{*)}	^{228}Ra	< det lim ^{#)}	^{228}Th	< det lim ^{#)}
^{235}U	24	^{227}Ac	0.5	^{223}Ra	0.5
^{238}U	520	^{226}Ra	< det lim ^{#)}	^{210}Pb	29




^{*)} detection limit XRF

^{#)} detection limit gamma-spectrometry

C/S Candle Contamination

C/S Candle β/γ External Radiation



Polyol Plants: NL (top row) & MY (bottom row)

Controlled Dismantling C/S Candle




Layer 1a



Layer 1a (detail)




Layer 1b




Polyol Plants NL & MY

SEM Images – Used & Fresh C/S Candle




PP-MY



Fresh material




PP-NL



Magnification 100 ×

1b



↔ = 100 µm

C/S Candle Contamination

NOR distribution over filter matrasses



	NOR total activity kBq	Distribution of Naturally Occurring Radionuclide (NOR)				
		layer 1a	layer 1b	layer 2	layer 3	layer 4
PP-NL						
²³⁸ U	316,6	96,3%	2,8%	0,4%	0,2%	0,1%
²³⁴ U	310,7	96,2%	3,5%	0,4%	0,0%	0,0%
²²⁶ Ra	0,2	100,0%	0,0%	0,0%	0,0%	0,0%
²¹⁰ Pb	15,7	98,8%	1,1%	0,1%	0,0%	0,0%
²³⁵ U	14,9	96,8%	2,6%	0,4%	0,1%	0,0%
PP-MY						
²³⁸ U	1,86	100,0%	0,0%	0,0%	0,0%	0,0%
²³⁴ U	2,02	100,0%	0,0%	0,0%	0,0%	0,0%
²²⁶ Ra	< det lim					
²¹⁰ Pb	0,01	100,0%	0,0%	0,0%	0,0%	0,0%
²³⁵ U	0,09	100,0%	0,0%	0,0%	0,0%	0,0%

Phosphoric Acid Production

Phosphate Rock (wet or thermal processing)



If a “system” is not closed to radionuclide migration (e.g. *ground phosphate rock during processing/digesting*), the secular equilibrium may become disturbed. A migrated *daughter* nuclide (^{226}Ra) may start a decay series for its own in its own preferred environment (*aqueous waste streams*), so-called *sub-series* will be formed.



NOR's encounter for Phosphate Industry (wet process)

	^{238}U	^{230}Th	^{226}Ra	^{210}Pb
<u>Products:</u> NPK Fertilisers	y	y	y/n	y/n
Phosphoric acid	y	n/y	n/y	n/y
<u>Waste:</u> Phosphogypsum	n	n	y	y
Aqueous streams	n	n	y	y
Stack	n	n	n	y

Phosphoric Acid (PA) Production

Phosphate Rock (wet > phosphogypsum or thermal > via elemental P)

Supplier Manufacturer	H ₃ PO ₄	Origin of sample	PA process	Grade type	Element (ppb)			
					Ti	Zr	Th	U
A	75%	supplier	wet	technical	1500	250	< 5	77
	75%	PP-NL	wet	technical	2150	230	< 5	70
	85%	supplier	wet	technical	2240	18		
	85%	supplier	wet	technical	2340	23	3	870
B	75%	supplier	wet	technical	2500	4130	< 5	440
	75%	PP-NL	wet	technical	4420	3210	< 5	1080
	85%	supplier	wet	technical	4060	4650	< 5	450
	85%	supplier	wet/+?	food	4470	4030	3	2040
	85%	supplier	wet/+?	food	4275	3630	5	1800
C	85%	PP-MY	wet/filter	food	14	7	7	< 5
	85%	supplier UK	wet/filter	food	120	170	< 5	8
	85%	supplier UK	wet/filter	food	110	160	< 2	3
D	75%	supplier NL	wet/filter	food	140	6	2	< 2
E	85%	PP-MY	wet/filter	food	190	21	6	1
F	75%	PP-NL	thermal	food	580	38	8	< 1
G	85%	supplier PRC	wet/filter	food	275	30	4	< 1
H	85%	PP-MY	wet/+?	food	1100	30	2	1
	85%	PP-MY	wet/+?	food	2700	400	1	42
I	85%	PP-MY	wet/+?	food	1200	12	1	< 1

C/S Candle Contamination – Deposit Analysis

deposit XRF analysis			PP-NL	PP-MY	(most likely)
Z	Symbol	M _A	w%	w%	originating from
15	P	31	10,5%	9,5%	H ₃ PO ₄
19	K	39	11,5%	9,5%	KOH
22	Ti	48	4,5%	4,5%	H ₃ PO ₄ impurity
24	Cr	52	2,5%	3,5%	AISI 316 L
26	Fe	56	22,5%	32,5%	AISI 316 L
28	Ni	59	1,0%	1,0%	AISI 316 L
40	Zr	91	4,0%		H ₃ PO ₄ impurity
92	U	238	7,0%	0,9%	H ₃ PO ₄ impurity
XRD morphology					
K ₂ Ti ₂ (PO ₄) ₃			Bulk	2 nd phase	KOH/H ₃ PO ₄
KTiOPO ₄			2 nd phase	3 rd phase	KOH/H ₃ PO ₄
KFe ₂ (OH)(PO ₄) ₂ (H ₂ O) ₂				Bulk	KOH/H ₃ PO ₄
Fe (metal)			3 rd phase		AISI 316 L
Cr (metal)			4 th phase		AISI 316 L
FeNi (alloy)			5 th phase		AISI 316 L
(UO ₂)HPO ₄ (3-x)H ₂ O			trace		H ₃ PO ₄ (imp)

Conclusions, Recommendations and Scope for PP-NL

Radiological License to Operate, Change PA Grade and Clearance

Conclusion

- U_{nat} impurities in phosphoric acid root cause for 'radioactive' deposits inside spent C/S candles
- Differences Spent C/S Candles from PP-NL and PP-MY:
 1. U_{nat} contents in PP-MY Candles substantially less than in PP-NL Candles
 2. PP-MY deposit texture very different from that in PP-NL candles
 3. Impurities/Impurity levels in Phosphorous Acid significantly different for PP-MY ('food grade') and PP-NL ('technical grade').
- PP-NL spent C/S candles classified as 'radioactive waste' and require licensing

Recommendation

- Change to food grade phosphoric acid
 - define impurity specifications for Ti, Zr, Th and U
 - control/monitor phosphoric acid intake (physical data base)

Scope

- 😊 C/S candles cleared from 'radioactive control regime' (proof/notification to competent authority)
- 😊 longer operational life time of C/S candles
- 😊 ultra-sonic cleaning of C/S Candle for regeneration (*cf.* PP-MY)

Dose Assessment C/S Candle Contamination

various handlings with C/S Candles

Worker Location	Operation	Workers	Assessed Doses (μSv)			natural background
			external	internal	total	
SRTCA	C/S Candle Transport PP-NL > SRTCA, incl. Regeneration Trials	2	0,1	-	0,1	6%
SRTCA	Cutting a C/S Candle Open for Demonstration Purposes, incl. Internal Transport and Storage in Office	1	1	5	6	6%
		2	1	-	1	
		1	0,3	-	0,3	
PP-NL	Candle Exchange in C/S Unit for Optimal Plant Operation	3	0,3	-	0,3	77%
PP-NL	Filter Exchange in Terrace Filter Unit for Optimal Plant Operation	4	1,5	-	1,5	460%
PP-NL	Cutting a C/S Candle Open for Deposit Sampling	2	2	5	7	89%
PP-NL	Sample Analysis at the Production Laboratory	2	0,5	4,5	5	32%

Conclusions from a Radiological Point of View

- Dose assessment fully focused on the SRTCA and PP-NL workforce
- Handlings with C/S Candles containing U_{nat} contaminated deposits do not give rise to doses exceeding the negligibility dose limit (10 $\mu\text{Sv/a}$)
 - apart from awareness no other measures from an HSE point of view required.
- a more comprehensive assessment should track the follow-up route of the U_{nat} contaminated Spent C/S Candles
 - scrap handling (scrap yard workers),
 - route of U_{nat} (and ^{210}Pb) during melting (melting plant workers)
 - any subsequent public and environmental exposure
- from a nuclear energy act point of view (fissionable material) a radiological license is required, but it would be questionable, if such a license would be required from a dose point of view